

KEMA Test Certificate

No. 2122754 .101

Issued to: Lectro Egypt
Borg El Arab Area No. 3
Alexandria
Egypt

For the product: low-voltage busbar trunking system (flange, straight lengths and joints)

Trade name: LECTRO BAR

Type/Model: LSB080

Ratings: Ie 800 A, Ue 1000 V, Ui 1000 V, Uimp 8 kV, 40 kA - 1,0 s

Manufactured by: Lectro Egypt
Borg El Arab Area No. 3
Alexandria
Egypt

Subject: Type tests

Requirements: IEC 60439-2, 3rd ed. 2000-03 and Amendment A1 2005-08; Clauses: 8.2.1, 8.2.2, 8.2.3, 8.2.4, 8.2.5, 8.2.7, 8.2.9, 8.2.10, 8.2.12 and 8.2.13

Remarks: -

This Test Certificate is granted on account of an examination by KEMA, the results of which are laid down in report no. 2122754.02-QUA/INC, dated September 28, 2009.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA

KEMA Quality B.V.
Arnhem, September 28, 2009



F.S. Strikwerda
Certification Manager

*Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.